

CERTIFICATE OF COMPLIANCE

Certificate Number 20150626-E222308
Report Reference E222308-20150626
Issue Date 2015-JUNE-26

Issued to: G M INTERNATIONAL S R L
VIA SAN FIORANO 70
20852 VILLASANTA MB ITALY

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS, PROCESS CONTROL
EQUIPMENT FOR USE IN ZONE CLASSIFIED
HAZARDOUS LOCATIONS.

For Models/Product Refer To Addendum Page.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

For Standard(s) Refer To Addendum Page.

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20150626-E222308
Report Reference E222308-20150626
Issue Date 2015-JUNE-26

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product

Associated Apparatus for use in Unclassified Locations or Class I, Division 2, Groups A, B, C, and D T4 and Class I, Zone 2 AEx nA [ia Ga] IIC T4 Gc, and Ex nA [ia Ga] IIC T4 Gc Hazardous Locations.

Models D5020, followed by S or D, provides intrinsically safe outputs for use in Class I, Division 1, Groups A, B, C, and D, Class II, Division 1, Groups E, F, and G, Class III and Class I, Zone 0, Group IIC, Zone 20, Group IIIC Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0274.

Standard(s) for Safety:

Standard No. UL 913, 8th Ed., Rev. 2015-04-28, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations

Standard No. ANSI/ISA 12.12.01-2013, Issued 2013-06-03, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

Standard No. UL 60079-0, 6th Ed., Issued 2013-07-26, Explosive atmospheres – Part 0: Equipment – General requirements

Standard No. UL 60079-11, 6th Ed., Rev. 2014-03-28, Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”

Standard No. UL 60079-15, 4th Ed., Rev. 2013-08-02 Explosive atmospheres – Part 15: Equipment protection by type of protection “n”

Standard No. UL 61010-1, 3rd Edition, Issued 2012-05-11 Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements

Standard No. CAN/CSA C22.2 No. 157-92, 3rd Ed., Rev. 2003-06, Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations

Standard No. CAN/CSA C22.2 No. 213-M1987, Issued 1987-03, Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

Standard No. CAN/CSA-C22.2 No. 60079-0:11, 2nd Ed., Issued 2011-12, Explosive atmospheres — Part 0: Equipment — General requirements

Standard No. CAN/CSA-C22.2 No. 60079-11:14, 2nd Ed., Issued 2014-02, Explosive atmospheres — Part 11: Equipment protection by intrinsic safety “i”

Standard No. CAN/CSA C22.2 No. 60079-15:12, Issued 2012-01, Electrical apparatus for explosive gas atmospheres — Part 15: Construction, test and marking of type of protection “n” electrical apparatus

Standard No. CAN/CSA C22.2 No. 61010-1-12, 3rd Edition, Issued 2012-05-11, “Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements”



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

