

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160401-E222308  
**Report Reference** E222308-20160331  
**Issue Date** 2016-APRIL-01

**Issued to:** G M INTERNATIONAL S R L  
Via G. Mameli, 53-55  
20852 Villasanta Mb ITALY

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS; PROCESS CONTROL  
EQUIPMENT FOR USE IN ZONE CLASSIFIED  
HAZARDOUS LOCATIONS

See Addendum Page for Models

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**  
**Additional Information:**

See Addendum Page for Standards

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160401-E222308  
**Report Reference** E222308-20160331  
**Issue Date** 2016-APRIL-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Associated Apparatus for use in Unclassified Locations or Class I, Division 2, Groups A, B, C, and D T4 and Class I, Zone 2, AEx nA [ia] IIC T4 Gc, and Ex nA [ia] IIC T4 Gc Hazardous Locations.

Models D5037, followed by S or D, provides intrinsically safe outputs for use in Class I, Division 1, Groups A, B, C, and D, Class II, Division 1, Groups E, F, and G, Class III and Class I, Zone 0, Group IIC, Zone 20, Group IIIC Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0277.

Associated Apparatus for use in Unclassified Locations or Class I, Division 2, Groups A, B, C, and D T4 and Class I, Zone 2, AEx nA nC [ia] IIC T4 Gc, and Ex nA nC [ia] IIC T4 Gc Hazardous Locations.

Models D5036, followed by S or D, provides intrinsically safe outputs for use in Class I, Division 1, Groups A, B, C, and D, Class II, Division 1, Groups E, F, and G, Class III and Class I, Zone 0, Group IIC, Zone 20, Group IIIC Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0277.

## Standard(s) for Safety:

UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations

ANSI/ISA 12.12.01-2013, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

UL 60079-0, Explosive atmospheres – Part 0: Equipment – General requirements

UL 60079-11, Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”

UL 60079-15, Explosive atmospheres – Part 15: Equipment protection by type of protection “n”

UL 61010-1, Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements

CAN/CSA C22.2 No. 157-92, Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations

CAN/CSA C22.2 No. 213-M1987, Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

CAN/CSA-C22.2 No. 60079-0:11, Explosive atmospheres — Part 0: Equipment — General requirements

CAN/CSA-C22.2 No. 60079-11:14, Explosive atmospheres — Part 11: Equipment protection by intrinsic safety “i”

CAN/CSA C22.2 No. 60079-15:12, Electrical apparatus for explosive gas atmospheres — Part 15: Construction, test and marking of type of protection “n” electrical apparatus

CAN/CSA C22.2 No. 61010-1-12, “Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements”



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

