

CERTIFICATE OF COMPLIANCE

Certificate Number E222308
Report Reference E222308-20181210
Date 2021-December-13

Issued to: G M INTERNATIONAL S R L
Via G. Mameli, 53-55
Villasanta Mb 20852 IT

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page for Standards.

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E222308
Report Reference E222308-20181210
Date 2021-December-13

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Models:

Associated Apparatus for use in Unclassified Locations or Class I, Division 2, Groups A, B, C and D, and Class I, Zone 2, AEx ec [ia] IIC and Ex ec [ia] IIC, Hazardous Locations.

Model D5062S, may be followed by “-XXX”, where –XXX are any alpha-numeric characters.

Provides intrinsically safe outputs for use in
Class I, Division 1, Groups A, B, C, and D;
Class II, Division 1, Groups E, F, and G;
*Class III;
Class I, Zone 0, Group IIC and
Zone 20, Group IIIC, Hazardous Locations when installed in accordance with manufacturer’s control drawing no. ISM0281.

Standards

UL 61010-1, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
CAN/CSA C22.2 No. 61010-1-12:16, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
UL 913, Standard for Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations
UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
UL 60079-0, Explosive Atmospheres – Part 0: Equipment - General Requirements
UL 60079-11, Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”
UL 60079-7, Explosive Atmospheres – Part 7: Equipment Protection by Increased safety “e”
CSA C22.2 NO 213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CAN/CSA C22.2 No. 60079-0:19, Explosive Atmospheres – Part 0: Equipment - General Requirements
CAN/CSA C22.2 No. 60079-11:14, Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”
CAN/CSA C22.2 No. 60079-7:16, Explosive Atmospheres – Part 7: Equipment Protection by Increased safety “e”



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>