

CERTIFICATE OF COMPLIANCE

Certificate Number 20190530-E498342
Report Reference E498342-20190524
Issue Date 2019-MAY-30

Issued to: G M INTERNATIONAL S R L
Via G. Mameli, 53-55, 20852 Villasanta Mb ITALY

**This certificate confirms that
representative samples of**

POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS FOR USE
IN HAZARDOUS LOCATIONS

USL/CNL – Rack-Mounted industrial power supplies, Open type, Model PSW1250, may be followed by –xxx, with x any alphanumeric character, for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.
Rack-Mounted industrial power supplies, Open type, Model PSS1250, may be followed by –HS, followed by 2, 3 or 7, followed by 1, 2, 3, 4, 6, 7, 8 or 9, may be followed by D, for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard No. UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
Standard No. CSA C22.2 No. 213-17, Nonincendive electrical equipment for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations

Additional Information:

See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

