

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E222308  
**Report Reference** E222308-20190601  
**Date** 2022-May-12

**Issued to:** G M INTERNATIONAL S R L  
Via G. Mameli, 53-55  
Villasanta Mb 20852 IT

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See Addendum Page for Standard(s).

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E222308  
**Report Reference** E222308-20190601  
**Date** 2022-May-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Product Designation(s):

USL, CNL – Associated Apparatus for use in Unclassified Locations or Class I, Division 2, Groups A, B, C and D; Class I, Zone 2, AEx nA [ia Ga] IIC T4 Gc; Ex nA [ia Ga] IIC T4 Gc X, Hazardous Locations.

\* Models D5072, followed by S or D, may be followed by “-087”, “-096”, “-099” or “-xxx”, where –xxx are any alpha-numeric characters, providing intrinsically safe outputs for use in  
Class I, Division 1, Groups A, B, C, and D;  
Class II, Division 1, Groups E, F, and G;  
Class III, Division 1;  
Class I, Zone 0, Group IIC and  
Zone 20, Group IIIC, Hazardous Locations when installed per Control Drawing no. ISM0282.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E222308  
**Report Reference** E222308-20190601  
**Date** 2022-May-12

Standard(s)

Standard	Title	Edition or Publication Date	Revision Date
UL 61010-1	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements	3rd Edition	2019-07-19
UL 913	Standard for Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations	Edition 8	12/06/2019
UL 121201	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations	Edition 9	04/01/2021
UL 60079-0	Explosive Atmospheres – Part 0: Equipment - General Requirements	Edition 6	10/20/2017
UL 60079-11	Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”	Edition 6	09/14/2018
UL 60079-15	Explosive Atmospheres – Part 15: Equipment Protection by Type of Protection “n”	Edition 4	05/05/2017
CSA C22.2 NO. 61010-1	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements	3rd Edition	2018-11
CSA C22.2 NO.213-17	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations	Edition 3	04/01/2021
CAN/CSA C22.2 No.60079-0:15	Explosive Atmospheres – Part 0: Equipment - General Requirements	Edition 3, Issue date 10/2015	-
CAN/CSA C22.2 No.60079-11:14	Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”	Edition 2, Issue date 02/2014	-
CAN/CSA C22.2 No.60079-15:16	Explosive Atmospheres – Part 15: Equipment Protection by Type of Protection “n”	Edition 2, Issue date 06/2016	-



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>