

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E222308  
**Report Reference** E222308-20190531  
**Date** 2022-May-12

**Issued to:** G M INTERNATIONAL S R L  
Via G. Mameli, 53-55  
Villasanta Mb 20852 IT

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See Addendum Page for Standard(s).

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E222308  
**Report Reference** E222308-20190531  
**Date** 2022-May-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

**Product Designation(s):**

USL, CNL – Process Control Equipment for use in Class I, Division 2, Groups A, B, C and D, Hazardous Locations.

Open type, Signal Converter, Model D6072, followed by S or D, may be followed by “-087”, “-096”, “-099” or “-xxx”, where –xxx are any alpha-numeric characters.

**Standard(s)**

Standard	Title	Edition or Publication Date	Revision Date
UL 61010-1	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements	3rd Edition	2019-07-19
UL 121201	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations	Edition 9	04/01/2021
CSA C22.2 NO. 61010-1	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements	3rd Edition	2018-11
CSA C22.2 NO.213-17	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations	Edition 3	04/01/2021



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

