

CERTIFICATE OF COMPLIANCE

Certificate Number 20130115-E222308E
Report Reference E222308-20110201
Issue Date 2013-JANUARY-15

Issued to: G M INTERNATIONAL S R L
VIA SAN FIORANO 70
20852 VILLASANTA MB ITALY

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS; PROCESS CONTROL
EQUIPMENT FOR USE IN ZONE CLASSIFIED
HAZARDOUS


See addendum for models.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See addendum for Standards.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130115-E222308E
Report Reference E222308-20110201
Issue Date 2013-JANUARY-15

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

MODELS:

Associated Apparatus for use in Unclassified Locations.

Signal converter isolator Model D1053S, may or may not be followed by /B, provides intrinsically safe circuits for use in Class I, Groups A, B, C, and D; Class II, Groups E, F, and G; and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0138.

Temperature converter isolator Model D1073S, may or may not be followed by /B, provides intrinsically safe circuits for use in Class I, Groups A, B, C, and D; Class II, Groups E, F, and G; and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0142.

Associated Apparatus for use in Class I, Division 2, Groups A, B, C, and D Hazardous Locations.

Signal converter isolators Models D1052S, D1052D, D1052X and D1052Y, may or may not be followed by /B, provide intrinsically safe circuits for use in Class I, Groups A, B, C, and D; Class II, Groups E, F, and G; and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0137.

Temperature converter isolators Models D1072S and D1072D, may or may not be followed by /B, provide intrinsically safe circuits for use in Class I, Groups A, B, C, and D; Class II, Groups E, F, and G; and Class III Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0141.

Associated Apparatus for use in Unclassified Locations, [AEx ia]; [Ex ia].

Signal converter isolator Model D1053S, may or may not be followed by /B, provides intrinsically safe circuits for use in Class I, Zone 0, Group IIC Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0138.

Temperature converter isolator Model D1073S, may or may not be followed by /B, provides intrinsically safe circuits for use in Class I, Zone 0, Group IIC Hazardous Locations when installed in accordance with manufacturer's control drawing no. ISM0142.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130115-E222308E
Report Reference E222308-20110201
Issue Date 2013-JANUARY-15

STANDARDS:

UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations
UL 1604, Electrical Equipment for Use in Class I and II, Division 2, and Class III Hazardous (Classified) Locations
UL 60079-0, Electrical Apparatus for Explosive Gas Atmospheres – Part 0: General Requirements
UL 60079-11, Electrical Apparatus for Explosive Gas Atmospheres – Part 11: Intrinsic Safety “i”
UL 60079-15, Electrical Apparatus for Explosive Gas Atmospheres – Part 15: Electrical Apparatus with Type of Protection “n”
UL 61010-1, Electrical Equipment For Measurement, Control, and Laboratory Use; Part 1: General Requirements
CSA C22.2 No. 157-92, Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations
CSA C22.2 No. 213, Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
CSA-E60079-0:02, Electrical apparatus for explosive gas atmospheres – Part 0: General requirements
CSA-E60079-11:02, Electrical apparatus for explosive gas atmospheres – Part 11: Intrinsic safety “i”
CSA E60079-15:02, Electrical apparatus for explosive gas atmospheres - Part 15: Type of protection “n”
CSA C22.2 No. 61010-1-04, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

