

Declaration of Conformity

G.M. International S.r.l.
declares that here below listed equipment:

D5000 series
D6000 series
TB-D5000 series
TBE-D5000 series

were tested by Auto Technology Company testing laboratory to the ANSI/ISA S71.04-1985 severity level G3 and the IEC 60068-2-60:2015 (test report n. ATL-5050-04-20).

G.M. products were tested with the following gas concentrations of the "group A":

Contaminant gas	Concentration G3 harsh
H ₂ S	50 ppb
SO ₂ , SO ₃	300 ppb
Cl ₂	10 ppb
NO _x	1250 ppb

After the testing, an optical inspection was performed, followed by a 100% functional test.
Under consideration of the results of this test we declare that the above-mentioned series models are compliant with the requirements of the "group A" contaminant gases.

Francesco Landrini
CEO

