



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: IECEx PRE 16.0084

Issue No: 0

Certificate history:

[Issue No. 0 \(2017-05-22\)](#)

Status: **Current**

Page 1 of 3

Date of Issue: **2017-05-22**

Applicant: **G.M. International S.r.l.**  
Via G. Mamell, 53/55  
I-20852 Villasanta (MB)  
**Italy**

Equipment: **Isolators**

*Optional accessory:*

Type of Protection: **ia**

Marking:

[Ex ia Ga] IIC -20°C ≤ Ta ≤ +60°C  
[Ex ia Ma] I -20°C ≤ Ta ≤ +60°C  
[Ex ia Da] IIIC -20°C ≤ Ta ≤ +60°C

*Approved for issue on behalf of the IECEx  
Certification Body:*

Asle Kaastad

*Position:*

Certification Manager

*Signature:  
(for printed version)*

*Date:*

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](#).

Certificate issued by:

**DNV Nemko Presafe AS**  
Gautadalleen 30  
P.O.Box 73 Blindern  
0314 Oslo  
Norway





# IECEX Certificate of Conformity

Certificate No: IECEX PRE 16.0084

Issue No: 0

Date of Issue: **2017-05-22**

Page 2 of 3

Manufacturer: **G.M. International S.r.l.**  
Via G. Mamell, 53/55  
I-20852 Villasanta (MB)  
**Italy**

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

**IEC 60079-0 : 2011** Explosive atmospheres - Part 0: General requirements  
Edition:6.0

**IEC 60079-11 : 2011** Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"  
Edition:6.0

*This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.*

## TEST & ASSESSMENT REPORTS:

*A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in*

Test Report:

[NO/PRE/ExTR16.0077/00](#)

Quality Assessment Report:

[NO/DNV/QAR07.0005/07](#)



# IECEX Certificate of Conformity

Certificate No: IECEx PRE 16.0084

Issue No: 0

Date of Issue: 2017-05-22

Page 3 of 3

## Schedule

### EQUIPMENT:

*Equipment and systems covered by this certificate are as follows:*

The D1054S series DIN Rail isolator is an associated apparatus designed as single channel galvanic isolator to interface intrinsically safe apparatus field devices located in hazardous area with non-intrinsically safe measuring and process control equipment located in safe area.

The D1061S series DIN Rail isolator is an associated apparatus designed as galvanic isolators to transfer bidirectional serial communication from hazardous area equipment and convert their signals to drive bidirectionally non-intrinsically safe digital communication systems located in safe area.

The D1063S series single DIN Rail strain gauge isolating repeater D1063S acts as a transparent galvanic isolated interface installed between a weighting indicator in safe area and load cell in hazardous area.

They are enclosed in a plastic enclosure suitable for installation on T35 DIN rails.

See the annex to this certificate for safety parameters.

**SPECIFIC CONDITIONS OF USE: NO**

### Annex:

[Annex to IECEx PRE 16.0084.pdf](#)

Annex to certificate: IECEx PRE 16.0084

Electric Safety Parameters:

D1054S

Input: Terminal 14-15-16 (Um) Input: Terminals 15-16			Output:		Output between +TX and +IN, Terminals 14 and 15		Output between +IN and -IN, Terminals 15 and 16	
Um:	250	V	Uo:		26,3	V	1,1	V
Ui:	30	V	Io:		91	mA	56	mA
Ii:	128	mA	Po:		597	mW	16	mW
Li:	0	mH	Lo:	I	70,0	mH	148	mH
				IIA	34,5	mH	90,7	mH
				IIB	17,2	mH	45,3	mH
				IIC	4,3	mH	11,3	mH
				IIIC	17,2	mH	45,3	mH
Ci:	1,05	nF	Co:	I	4,39	μF	1000	μF
				IIA	2,51	μF	1000	μF
				IIB	738	nF	1000	μF
				IIC	95	nF	100	μF
				IIIC	738	nF	1000μF	μF
			Lo/Ro	I	782,2	μH/Ω	30,55	mH/Ω
				IIA	476,8	μH/Ω	18,618	mH/Ω
				IIB	238,4	μH/Ω	9,309	mH/Ω
				IIC	59,6	μH/Ω	2,327	mH/Ω
				IIIC	238,4	μH/Ω	9,309	mH/Ω

D1061S

Input:		Output:			
Um:	250V	Uo:	3,7	V	
Ui:	30V DC	Io:	225	mA	
Ii:	282 mA	Po:	206	mW	
Li:	0	Lo:	I	11,75	mH
			IIA	5,6	mH
			IIB	2,8	mH
			IIC	0,7	mH
			IIIC	2,8	mH
Ci	0	Co:	I	1000	μF
			IIA	1000	μF
			IIB	1000	μF
			IIC	100	μF
			IIIC	1000	μF
		L <sub>0</sub> /R <sub>0</sub> :	I	2274	μH/Ω
			IIA	1386	μH/Ω
			IIB	693	μH/Ω
			IIB	173	μH/Ω
			IIIC	693	μH/Ω

Annex to certificate: IECEx PRE 16.0084

D1063S

Input: Terminal 1 to 8 (Um) Input: Terminal 13-14			Output:		Output terminal 9,10,11,12(including terminals 13 and 14)		Output terminals 13 and 14	
Um:	250	V	Uo:		17,3	V	17,3	V
Ui:	30	V	Io:		199,6	mA	7	mA
			Po:		860	mW	31	mW
Li:	0	mH	Lo:	I	11,75	mH	3,93	H
				IIA	6,8	mH	2,4	H
				IIB	3,4	mH	1,2	H
				IIC	0,85	mH	0,3	H
				IIIC	3,4	mH	1,2	H
Ci:	2,1	nF	Co:	I	11,79	μF	11,8	μF
				IIA	8,5	μF	8,5	μF
				IIB	2,06	μF	2,06	μF
				IIC	351	nF	353	nF
				IIIC	2,06	μF	2,06	μF
			Lo/Ro:	I	543,25	μH/Ω	15,47	mH/Ω
				IIA	329,6	μH/Ω	8,22	mH/Ω
				IIB	164,8	μH/Ω	4,11	mH/Ω
				IIC	41,2	μH/Ω	1,02	mH/Ω
				IIIC	164,8	μH/Ω	4,11	mH/Ω