

Certificate of Compliance

Certificate Number(s):

UL-US-L222308-47791-
92907102-1
UL-US-L222308-47731-
92907102-1

Report Reference:

E222308-20170929

Issue Date:

2025-09-29

Issued to:

G M INTERNATIONAL S R L
Via G. Mameli, 53-55, Villasanta, MB, 20852, IT

This certificate confirms that representative samples of:

**QVAJ - Process Control Equipment for Use in Zone Classified
Hazardous Locations**

**QUZW - Process Control Equipment for Use in Hazardous
Locations**

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 61010-1, 3rd Ed., Issue Date: 2012-05-11, Revision Date: 2023-06-06

UL 60079-0, Edition 7, Issue Date 2019-03-26, Revision Date 2024-07-19

UL 60079-11, Edition: 6, Issue Date: 2013-02-15, Revision Date: 2023-01-25

UL 60079-7, 5th Ed., Issue Date: 2017-02-24, Revision Date: 2021-06-03

UL 913, Edition 8, Issue Date 2013-12-06, Revision Date 2022-05-10

UL 121201, 9th Ed., Issue Date: 2017-09-15, Revision Date: 2021-04-01

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-L222308-47791-92907102-1, UL-US-L222308-47731-92907102-1
Report reference: E222308-20170929
Issue Date: 2025-09-29

does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

© 2025 UL LLC. All rights reserved.
Form-ULID-019496 – ver 1.0

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-L222308-47791-92907102-1, UL-US-L222308-47731-92907102-1
Report reference: E222308-20170929
Issue Date: 2025-09-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Process Control Equipment for HazLoc

Model(s): D526 followed by 3 or 4, followed by S, may be followed by XXX where XXX are any alphanumeric characters not affecting concept of protection

Associated apparatus, Load Cell/Strain Gauge Isolators

Model(s): D526 followed by 3 or 4, followed by S, may be followed by -XXX where XXX are any alphanumeric characters not affecting concept of protection, provides intrinsically safe outputs for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, Class III hazardous locations when installed in accordance with manufacturer's control drawing no. ISM0290.

Load Cell/Strain Gauge Isolators

Model(s): D5264, D5263 followed by S, may be followed by XXX where XXX are any alphanumeric characters not affecting concept of protection.

Certificate of Compliance

Certificate Number(s):

UL-CA-L222308-47761-
92907102-1
UL-CA-L222308-47821-
92907102-1

Report Reference:

E222308-20170929

Issue Date:

2025-09-29

Issued to:

G M INTERNATIONAL S R L
Via G. Mameli, 53-55, Villasanta, MB, 20852, IT

This certificate confirms that representative samples of:

QUZW7 - Process Control Equipment for Use in Hazardous Locations Certified for Canada

QVAJ7 - Process Control Equipment for Use in Zone Classified Hazardous Locations Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CAN/CSA-C22.2 No. 61010-1-12, Edition 3, Issue Date 2012-05-11, Revision Date 2023-06

CSA C22.2 NO. 213-17, 3rd Ed., Issue Date: 2017-09-15, Revision Date: 2021-04-01

CSA C22.2 NO. 60079-0, Edition 4, Issue Date: 2019-02-01

CSA C22.2 NO. 60079-11, Edition 2, Issue Date: 2014-02-01

CSA C22.2 No. 60079-11, Edition 2, Issued 2014-02-01

CSA C22.2 No. 60079-7, Edition 2, AMD 1, Issue Date 2016-10, Revision Date 2018-09

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-L222308-47761-92907102-1, UL-CA-L222308-47821-92907102-1
Report reference: E222308-20170929
Issue Date: 2025-09-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Process Control Equipment for HazLoc

Model(s): D526 followed by 3 or 4, followed by S, may be followed by XXX where XXX are any alphanumeric characters not affecting concept of protection

Associated apparatus, Load Cell/Strain Gauge Isolators

Model(s): D526 followed by 3 or 4, followed by S, may be followed by -XXX where XXX are any alphanumeric characters not affecting concept of protection, provides intrinsically safe outputs for use in Class I, Division 1, Groups A, B, C and D, Class II, Division 1, Groups E, F and G, Class III hazardous locations when installed in accordance with manufacturer's control drawing no. ISM0290.

Load Cell/Strain Gauge Isolators

Model(s): D5264, D5263 followed by S, may be followed by XXX where XXX are any alphanumeric characters not affecting concept of protection.