

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E222308  
**Report Reference** E222308-20190204  
**Date** 2020-December-04

**Issued to:** G M INTERNATIONAL S R L  
Via G. Mameli, 53-55  
VillasantaMb 20852 IT

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS - COMPONENT

Open Type – DIN Rail Termination Board 16 positions,  
model TB, may be followed by E, followed by -D5016-TRI-  
010 and Termination Board 8 positions, model TB-D5008-  
INV-005, for use in Class I, Division 2, Groups A, B, C and  
D, Hazardous Locations.

Have been investigated by UL in accordance with the  
component requirements in the Standard(s) indicated on  
this Certificate. UL Recognized components are incomplete  
in certain constructional features or restricted in  
performance capabilities and are intended for installation in  
complete equipment submitted for investigation to UL LLC.

**Standard(s) for Safety:** See Addendum Page for Standards

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

*This Certificate of Compliance* does not provide authorization to apply the UL Recognized Component Mark.  
Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified  
and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E222308  
**Report Reference** E222308-20190204  
**Date** 2020-December-04

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

**Standards:**

UL 61010-1, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

CAN/CSA C22.2 No. 61010-1, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

CSA C22.2 No. 213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

