



# 中国国家强制性产品认证证书



证书编号: 2023322308005685

认证委托人名称: G. M. INTERNATIONAL S. R. L.  
 认证委托人地址: Corso di Porta Vittoria 28, I-20122 Milano (MI) Italy  
 生产者名称: G. M. INTERNATIONAL S. R. L.  
 生产者地址: Corso di Porta Vittoria 28, I-20122 Milano (MI) Italy  
 生产企业名称: G. M. INTERNATIONAL S. R. L.  
 企业地址: Via G. Mameli 53/55 I-20852 Villasanta (MB) Italy

产品名称: 底座板  
 系列、规格、型号: TB/TBE 系列  
 标准: GB/T 3836.1-2021、GB/T 3836.3-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。产品相关信息详见附件。

发证日期: 2023年12月05日

有效期至: 2028年12月04日

首次发证日期: 2023年12月05日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准:



## 上海仪器仪表自控系统检验测试所有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2023322308005685**

**APPLICANT:** G.M. INTERNATIONAL S.R.L.  
**ADDRESS:** Corso di Porta Vittoria 28, I-20122 Milano (MI) Italy  
**MANUFACTURER:** G.M. INTERNATIONAL S.R.L.  
**ADDRESS:** Corso di Porta Vittoria 28, I-20122 Milano (MI) Italy  
**FACTORY:** G.M. INTERNATIONAL S.R.L.  
**ADDRESS:** Via G. Mameli 53/55 I-20852 Villasanta (MB) Italy

**PRODUCT:** Termination board  
**SERIES,SPECIFICATION,MODEL:** TB/TBE Series  
**STANDARDS:** GB/T 3836.1-2021、GB/T 3836.3-2021

**Type of Certification: Type test + Initial inspection + Surveillance inspection**  
 This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).  
 Refer to the attachment for detailed information.


**Valid from:**December 5, 2023 **Valid until:**December 4, 2028

**Date of original certification:**December 5, 2023

**The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.**

This certificate is available through CNCA’s website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:   
 Guo AiHua



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**



# 中国国家强制性产品认证证书



证书编号: 2023322308005685

## 附 件

产品名称: 底座板

型号规格: TB-D5016-TRI-010  
TBE-D5016-TRI-010  
TB-D5008-INV-005  
TBE-D5008-TRI-001  
TBE-D5016-TRI-001  
TBE-D5016-TRI-002  
TBE-D5016-TRI-003  
TBE-D5016-TRI-004  
TBE-D5016-TRI-005  
TBE-D5016-TRI-006  
TBE-D5016-TRI-007  
TBE-D5016-TRI-008  
TBE-D5016-TRI-009  
TBE-D5016-TRI-011  
TBE-D5016-TRI-012

防爆标志: Ex ec IIC T4 Gc

电气参数: Un=24V dc (电压范围为: 20~30V dc)

相关报告编号: 2023S17402-013002

批 准:



## 上海仪器仪表自控系统检验测试所有限公司



# 中国国家强制性产品认证证书



证书编号：2023322308005685

## 附 件

使用条件：

3. 特殊（限制）使用条件

- 1) 产品使用环境温度范围为： $-40^{\circ}\text{C}\sim+70^{\circ}\text{C}$ 。
- 2) 产品只应在污染程度不低于 2 级的区域使用。（污染等级的定义见 GB/T16935.1）。
- 3) 产品应安装在外壳防护等级至少为 IP54（GB/T3836.1-2021）的外壳中。
- 4) 瞬态保护应提供不超过产品的供电端子额定峰值电压值 140%的保护。

批 准：



上海仪器仪表自控系统检验测试所有限公司