

Characteristics:
General description:

This Termination Board (TB) provides direct connection between the I/O Card of the system and D5000 Series modules. The Intrinsically Safe protection and signal isolation between Safe and Hazardous Area is provided by D5000 Series Associated Apparatus. The 24 Vdc Power Supply of the TB is connected to two plug-in terminal blocks, for a redundant power supply. The power supply for modules is given by TB power bus.

Termination Board general characteristics:

Termination Board Model	Number of positions	Features
TB-D5016-YOK-003	16	1) I/O Card redundancy; 2) Power Supply voltage redundancy; 3) Abnormal supply voltage signaling; 4) Cumulative module fault signaling.

Supported Yokogawa Centum VP I/O Cards:

I/O Card Model	I/O Card Type	Number of channels per I/O Card	Number of I/O Cards per board	Number of channels per board	Supported GM Modules
ADV151	Digital In	32	1+(1)*	32	D5031D D5032D
ADV161		64	1/2+(1/2)**	32	

* with possibility of I/O Card redundancy.

** with possibility of I/O Card redundancy.

Two TB-D5016-YOK-003 boards are necessary to provide 64 channels to I/O card (32 channels each)

Features:

- DI card type ADV151 (32 channels) Digital Input board interface.
- DI card type ADV161 (64 channels) Digital Input board interface.
- 16 positions Terminal Board for up to 32 channels.
- Lower cables installation and maintenance costs.
- Power supplies fault monitoring.
- Spare fuse provided.
- Mounting hardware provided for:
 - Single Din Rail mounting kit;
 - Wall mounting, M4 self tapping screw;
 - Wall mounting, M4 thread screw.

Ordering Information:

Model: TB-D5016-YOK-003

Technical Data:
Supply:

24 Vdc nom (20 to 30 Vdc) reverse polarity protected, double terminal blocks for redundant power supply, with OR diodes to mix supply voltages.

Connection: by polarized plug-in disconnect screw terminal blocks to accommodate terminations up to 2.5 mm².

Protection fuse: 4 A slow blow (spare fuse provided on Termination Board).

Fault detection: (for more information see Fault Logic section)

Abnormal supply voltages or module cumulative fault: PWR 1 or PWR 2 is in under (< 18 Vdc) or over (> 30 Vdc) voltage condition OR module cumulative fault indication.

Relay fault signaling: a voltage free NE SPST-1 Form A relay contact (de-energized in fault condition), with the following characteristics:

Contact material: AgCdO.

Contact rating: 2 A 36 Vac 72 VA, 2 A 48 Vdc 80 W (resistive load).

Mechanical / Electrical life: 30 * 10⁶ / 1 * 10⁵ operation, typical.

Connection: by polarized plug-in disconnect screw terminal blocks to accommodate terminations up to 2.5 mm².

LED fault signaling: 1 green LED (PWR 1 OK); 1 green LED (PWR 2 OK);

1 red LED (UV or OV of PWR 1); 1 red LED (UV or OV of PWR 2);

a cumulative fault red LED.

Centum VP I/O card interface:

Connection: two 50 poles male connectors (require female mating connectors).

Field signal:

Connection: directly to module by polarized plug-in disconnect screw terminal blocks to accommodate terminations up to 2.5 mm².

Environmental conditions:

Operating: temperature limits – 40 to + 70 °C,

relative humidity max 90 % non condensing, up to 35 °C.

Storage: temperature limits – 45 to + 80 °C.


Mounting:

Hardware included for mounting on wall and single DIN rail.

Weight: about 400 g (excluding modules and mounting options).

Location: Safe Area / Ordinary locations.

Dimensions: Width 267 mm, Depth 176 mm, Height 125 mm.


Image:


Loop Diagrams for Centum VP ADV151 (32 DI) Interface Card:


HAZARDOUS AREA

SAFE AREA

TB position 1 to 16 for double channel DI module (Transistor Output)



TB position 1 to 16 for double channel DI module (Relay Output)




Loop Diagrams for Centum VP ADV161 (64 DI) Interface Card:


HAZARDOUS AREA

SAFE AREA

TB position 1 to 16 for double channel DI module (Transistor Output)



TB position 1 to 16 for double channel DI module (Relay Output)





Termination Board Description:

Note:

Relay contact is defined Normally Closed (NC) or Normally Open (NO) when RL1 or RL2 relays are de-energized (that is, coil status LED is turned off). Relay is de-energized in fault status.

HAZARDOUS AREA / LOCATION

SAFE AREA / ORDINARY LOCATION




Termination Board Fault Logic:

LED Signaling:

Meaning of LEDs on termination boards:


TAG	LED COLOR	MEANING
PWR 1 OK	GREEN	The LED is on when PWR 1 is within the regular range (>18 V and <30 V).
PWR 1 Over or Under V	RED	The LED is on when PWR 1 is in over-voltage (>30V) or under-voltage (<18 V).
PWR 2 OK	GREEN	The LED is on when PWR 2 is within the regular range (>18 V and <30 V).
PWR 2 Over or Under V	RED	The LED is on when PWR 2 is in over-voltage (>30V) or under-voltage (<18 V).
Cumulative Fault	RED	The LED is on when at least one module / barrier reported a fault.





Relay Activation Conditions:

The two relays are activated according to the following rules:

TAG	ACTIVATION
ALARM	The relay is energized when the following two conditions hold: <ol style="list-style-type: none"> both supply voltages are within the regular range (>18 V and <30 V). No module / barrier fault is reported.





SAFE AREA / ORDINARY LOCATION




HAZARDOUS AREA / LOCATION

HAZARDOUS AREA / LOCATION




SAFE AREA / ORDINARY LOCATION




HAZARDOUS AREA / LOCATION

DIN Rail mounting overall dimensions:

Bottom view




Side view



All dimensions are expressed in millimeters [inches]


Mounting features kit TB-OPT-001




Ref. Nr	Q.ty	Description	Material
1	2	T35 Din Rail Adapter	PA
2	6	3.5 x 9.5 Self tapping screw	Stainless Steel
3	6	M3 External Tooth lock Washer	Stainless Steel
4	6	M3 Washer	Stainless Steel
5	2	6 c 20 Spacer	PA

Wall mounting overall dimensions for M4 self tapping screw:

Bottom view





Side view



All dimensions are expressed in millimeters [inches]


Mounting features kit TB-OPT-001




Ref. Nr	Q.ty	Description	Material
6	4	M4 x 8 Screw	Stainless Steel
7	4	M4 External Tooth lock Washer	Stainless Steel
8	8	M4 Washer	Stainless Steel
9	4	Self Tapping Spacer	NI - Plated Brass

Wall mounting overall dimensions for M4 thread screw:

Bottom view





Side view




All dimensions are expressed in millimeters [inches]

Mounting features kit TB-OPT-001



Ref. Nr	Q.ty	Description	Material
10	4	M4 x 8 Screw	Stainless Steel
11	8	M4 External Tooth lock Washer	Stainless Steel
12	8	M4 Washer	Stainless Steel
13	4	Threaded Spacer	NI - Plated Brass
14	4	M4 Nut	Stainless Steel

Connections table to Interface Card:

FIELD DEVICE	MODULE TYPE	MODULE FUNCTION	MODULE POSITION	MODULE CHANNEL NUMBER	INTERFACE CARD CHANNEL NUMBER	INTERFACE CARD CONNECTOR PIN NUMBER	INTERFACE CARD REDUNDANT CONNECTOR PIN NUMBER	NOTE
	D5031D, D5032D, (Double channel)	Digital Input	1	1A	1	(-) 50 (CN1)	(-) 50 (CN2)	<ul style="list-style-type: none"> Interface Card Connectors CN1, CN2: 50 poles male. For Interface Card channel number 1 to 16, the poles No. 12, 14, 16, 18 are Common poles, connected to GND of TB. For Interface Card channel number 17 to 32, the poles No. 11, 13, 15, 17 are Common poles, connected to GND of TB. The poles from No. 3 to No. 10 are not connected because not used. The poles No. 1 and No. 2 are connected together. For each channel, the positive pole of signal is connected to +24 Vdc supply of TB.
			2	2A	2	(-) 48 (CN1)	(-) 48 (CN2)	
			3	3A	3	(-) 46 (CN1)	(-) 46 (CN2)	
			4	4A	4	(-) 44 (CN1)	(-) 44 (CN2)	
			5	5A	5	(-) 42 (CN1)	(-) 42 (CN2)	
			6	6A	6	(-) 40 (CN1)	(-) 40 (CN2)	
			7	7A	7	(-) 38 (CN1)	(-) 38 (CN2)	
			8	8A	8	(-) 36 (CN1)	(-) 36 (CN2)	
			9	9A	9	(-) 34 (CN1)	(-) 34 (CN2)	
			10	10A	10	(-) 32 (CN1)	(-) 32 (CN2)	
			11	11A	11	(-) 30 (CN1)	(-) 30 (CN2)	
			12	12A	12	(-) 28 (CN1)	(-) 28 (CN2)	
			13	13A	13	(-) 26 (CN1)	(-) 26 (CN2)	
			14	14A	14	(-) 24 (CN1)	(-) 24 (CN2)	
			15	15A	15	(-) 22 (CN1)	(-) 22 (CN2)	
			16	16A	16	(-) 20 (CN1)	(-) 20 (CN2)	
			1	1B	17	(-) 49 (CN1)	(-) 49 (CN2)	
			2	2B	18	(-) 47 (CN1)	(-) 47 (CN2)	
			3	3B	19	(-) 45 (CN1)	(-) 45 (CN2)	
			4	4B	20	(-) 43 (CN1)	(-) 43 (CN2)	
			5	5B	21	(-) 41 (CN1)	(-) 41 (CN2)	
			6	6B	22	(-) 39 (CN1)	(-) 39 (CN2)	
			7	7B	23	(-) 37 (CN1)	(-) 37 (CN2)	
			8	8B	24	(-) 35 (CN1)	(-) 35 (CN2)	
			9	9B	25	(-) 33 (CN1)	(-) 33 (CN2)	
			10	10B	26	(-) 31 (CN1)	(-) 31 (CN2)	
			11	11B	27	(-) 29 (CN1)	(-) 29 (CN2)	
			12	12B	28	(-) 27 (CN1)	(-) 27 (CN2)	
			13	13B	29	(-) 25 (CN1)	(-) 25 (CN2)	
			14	14B	30	(-) 23 (CN1)	(-) 23 (CN2)	
			15	15B	31	(-) 21 (CN1)	(-) 21 (CN2)	
			16	16B	32	(-) 19 (CN1)	(-) 19 (CN2)	

Termination Board supply connection details:

