



EAC Safety Instruction Manual

D5000 series



Note: This manual contains only safety instructions.

For the complete installation and user manuals, data sheets and certificates, supplier code of conduct, code of ethics, terms and conditions of sale and warranty please refer to www.gminternational.com.

Summary

1	Installation information	3
1.1	General	3
1.2	Installation for intrinsically safe associated apparatus application.....	3
1.3	Installation for zone 2 application	4
1.3.1	Special conditions for safe use	4
1.4	Inspection, maintenance and repair	4
2	Certification data.....	4
2.1	Table 1: Certificates and operating temperature	4
2.2	Table 2: Contacts ratings	7
3	Intrinsically safe parameters	8

G.M. International Srl Via G. Mameli, 53/55, 20852, Villasanta, MB Italy	Title	Number	Date	Prepared by	Approved by
	EAC Safety Instruction Manual	ISM0642-0			

Copyright © GM International srl. All rights reserved. Any part of this document must not be reproduced without the written permission of G.M. International srl.

1 Installation information

1.1 General

D5000 series are apparatus installed into standard EN/IEC60715 (GOST R IEC 60715) TH 35 DIN-Rail located in Safe Area or Zone 2 within the specified operating temperature limits (for complete details please refer to table 1). They can be mounted with any orientation over the entire ambient temperature range.

The end user is responsible to ensure that the operating temperature of the module is not exceeded in the end use application.

Units must be protected against dirt, dust, extreme mechanical (e.g. vibration, impact and shock) and thermal stress, and casual contacts.

Electrical connections are accommodated by polarized removable screw terminal blocks which can be plugged in/out into a powered unit without suffering or causing any damage. Connect only one individual conductor per each clamping point, use conductors up to 2.5 mm² and a torque value of 0.5-0.6 Nm. The wiring cables have to be proportionate in base to the current and the length of the cable.

D5000 series must be installed, operated and maintained only by qualified personnel, in accordance to the relevant national/international installation standards (e.g. EN/IEC 60079-14 (GOST IEC 31610.14) Explosive atmospheres - Part 14: Electrical installations design, selection and erection), following the established installation rules.

According to EN/IEC61010 (GOST IEC 61010.1), D5000 power supplies must be connected to SELV or SELV-E supplies.

All circuits connected to D5000 must comply with the overvoltage category II (or better) according to EN/IEC 60664-1 (GOST IEC 60664.1).

Failure to properly installation or use of the equipment may risk to damage the unit or severe personal injury.

For those models having a relay output: connect relay contacts checking the load rating to be within the contact maximum rating. To prevent relay contacts from damaging, connect an external protection (fuse or similar), chosen according to the relay breaking capacity diagram from installation instructions (for complete details please refer to table 2, if present).

For those models having a transistor output: connect transistor contacts checking the load rating to be within the contact maximum rating (for complete details please refer to table 2, if present).

For those models having contacts rated more than 50 Vac or 75 Vdc: de-energize main power source (turn off power supply voltage) and disconnect plug-in terminal blocks before opening the enclosure to avoid electrical shock when connected to live hazardous potential.

Storage: if the unit is not installed directly on a system (parts for spare or expansion with long storage periods), it must be conveniently stocked. Stocking area characteristics must comply with the following parameters: temperature -45 to +80°C; humidity 0 to 95%.

Vibration: no prolonged vibration should be perceivable in the stocking area to avoid loosening of parts or fatigue ruptures of components terminals.

Pollution: presence of pollutant or corrosive gases or vapours must be avoided to prevent corrosion of conductors and degradation of insulating surfaces.

For complete instruction manual, datasheet and certifications please refer to our website www.gminternational.com.

1.2 Installation for intrinsically safe associated apparatus application

D5000 series must be connected to equipment with a maximum limit for power supply U_m of 250 Vrms or Vdc. Not to be connected to control equipment that uses or generates more than 250 Vrms or Vdc with respect to earth ground.

Intrinsically safe conductors must be identified and segregated from non I.S. and wired in accordance to the relevant national/international installation standards (e.g. EN/IEC 60079-14 (GOST IEC 31610.14) Explosive atmospheres - Part 14: Electrical installations design, selection and erection), make sure that conductors are well isolated from each other and do not produce any unintentional connection.

Warning: substitution of components may impair intrinsic safety.

In the system safety analysis, always check that field device maximum allowable voltage, current and power are not exceeded by the safety parameters of the D5000 series associated apparatus connected to it. Check also that added connecting cable and field device capacitance and inductance do not exceed the limits given in the associated apparatus parameters for the effective gas group (Co, Lo, Lo/Ro).

Associated apparatus		Field device
Uo	≤	Ui
Io	≤	Ii
Po	≤	Pi
Co	≥	Ci + Ccable
Lo	≥	Li + Lcable
Lo/Ro	≥	Li/Ri and Lcable/Rcable

When used with separate powered intrinsically safe devices, check also that maximum allowable voltage, current and power of the D5000 series associated apparatus are not exceeded by the safety parameters of the field device.

Associated apparatus		Field device
Ui	≥	Uo
Ii	≥	Io
Pi	≥	Po
Ci + Ccable	≤	Co
Li + Lcable	≤	Lo

See parameters indicated in "Intrinsically safe parameters" section.

For installations in which both the Ci and Li of the field device exceed 1% of the Co and Lo parameters of the associated apparatus (excluding the cable), then 50% of Co and Lo parameters are applicable and shall not be exceeded (50% of the Co and Lo become the limits which must include the cable such that Ci device + C cable ≤ 50% of Co and Li device + L cable ≤ 50% of Lo). The reduced capacitance of the external circuit (including cable) shall not be greater than 1 μF for Groups I, IIA, IIB, IIIC and 600 nF for Group IIC. If the cable parameters are unknown, the following value may be used: Capacitance 200 pF per meter (60 pF per foot), inductance 1 μH per meter (0.20 μH per foot).

1.3 Installation for zone 2 application

De-energize power source (turn off power supply voltage) before plug or unplug the terminal blocks or before servicing, unless area is known to be nonhazardous.

Warning: substitution of components may impair suitability for zone 2.

Electrostatic Hazard: to avoid electrostatic hazard, the enclosure of D5000 series must be cleaned only with a damp or antistatic cloth.

1.3.1 Special conditions for safe use

The equipment shall only be used in an area of at least pollution degree 2, as defined in EN/IEC 60664-1 (GOST IEC 60664.1). When installed in zone 2, the unit shall be installed in an enclosure that provides a minimum ingress protection of IP54 in accordance with EN/IEC 60079-0 (GOST 31610.0). The enclosure must have a door or cover accessible only by the use of a tool.

1.4 Inspection, maintenance and repair

The unit cannot be repaired by the end user and must be returned to the manufacturer or his authorized representative.

If enclosure needs to be cleaned use only a cloth lightly moistened by a mixture of detergent in water.

2 Certification data

2.1 Table 1: Certificates and operating temperature

Model family	Certificate n.	Standards	Markings	Operating temperature
D5011	EA3C RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [Ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 ÷ 70 °C

Model family	Certificate n.	Standards	Markings	Operating temperature
D5014	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5015	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5016	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5020	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5030	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5031	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5032	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5034	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5036	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.15-2014 GOST 31610.7-2015	2Ex ec nC [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5037	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5038	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5039	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5040	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5048	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5049	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5062	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5072	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5072-087	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C

Model family	Certificate n.	Standards	Markings	Operating temperature
D5072-096	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	40 + 70 °C
D5072-099	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5090	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 + 70 °C
D5090-086	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 + 70 °C
D5091	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 + 70 °C
D5093	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.7-2015	2Ex ec IIC T4 Gc X	-40 + 70 °C
D5094	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.15-2014 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 + 70 °C
D5095	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.15-2014 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 + 70 °C
D5096	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.15-2014 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 + 70 °C
D5097	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.15-2014 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 + 70 °C
D5098	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 + 70 °C
D5099	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.15-2014 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 + 70 °C
D5202	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.15-2014 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 + 70 °C
D5212	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5231	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5240	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5244	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5254	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C
D5263	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 + 70 °C

Model family	Certificate n.	Standards	Markings	Operating temperature
D5264	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 ÷ +70 °C
D5273	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.15-2014 GOST 31610.7-2015	2Ex ec nC [ia Ga] IIC T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 ÷ +70 °C
D5290	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 ÷ +60 °C
D5290-078	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 ÷ +60 °C
D5291	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 ÷ +60 °C
D5293	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 ÷ +70 °C
D5294	EAЭC RU C-IT.EX01.B.00018/19	GOST 31610.0-2019 GOST 31610.15-2020 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 ÷ +70 °C
D5295	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.15-2014 GOST 31610.7-2015	2Ex ec nC IIC T4 Gc X	-40 ÷ +70 °C
PSD5201	EAЭC RU C-IT.AA87.B.00765/21	GOST 31610.0-2019 GOST 31610.11-2014 GOST 31610.7-2015	2Ex ec [ia Ga] IIB T4 Gc X [Ex ia Da] IIIC X [Ex ia Ma] I X	-40 ÷ +70 °C

2.2 Table 2: Contacts ratings

Model family	Contacts type	Contacts function	Contacts ratings
D5020	Transistor	Fault	100 mA at 35 Vdc (≤ 1.5 V voltage drop)
D5030	Relay	Load	4 A 250 Vac 1000 VA, 4 A 250 Vdc 120 W resistive load
D5031	Transistor	Out	100 mA at 35 Vdc (≤ 1.5 V voltage drop)
D5032	Relay	Out	100 mA 50 Vac 5 VA, 100 mA 50 Vdc 5 W resistive load
D5036	Relay	Out	4 A 250 Vac 1000 VA, 4 A 250 Vdc 120 W resistive load
D5037	Transistor	Out	100 mA at 35 Vdc (≤ 1.5 V voltage drop)
D5048	Transistor	Fault	100 mA at 35 Vdc (≤ 1.5 V voltage drop)
D5049	Transistor	Fault	100 mA at 35 Vdc (≤ 1.5 V voltage drop)
D5072	Transistor	Alarm	100 mA at 60 Vdc (≤ 1 V voltage drop)
D5072-099	Transistor	Alarm	100 mA at 60 Vdc (≤ 1 V voltage drop)
D5090	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load
D5090-086	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load
D5091	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load
D5093	Transistor	Out	50 mA at 35 Vdc (≤ 1 Vdc voltage drop)
D5094	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load
D5095	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load
D5096	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load
	Transistor	Fault	100 mA at 35 V (≤ 1.0 V voltage drop)
D5097	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load
	Transistor	Fault	100 mA at 35 V (≤ 1.0 V voltage drop)
D5098	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load
D5099	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load

Model family	Contacts type	Contacts function	Contacts ratings
D5202	Relay	Fault	4 A 250 Vac 1000 VA, 4 A 250 Vdc 120 W resistive load
D5212	Transistor	Alarm	100 mA at 60 V (≤ 1.0 V voltage drop)
D5231	Transistor	Out	100 mA at 35 V (≤ 1.0 V voltage drop)
D5244	Relay	Load	40 Vdc, 2 A (I.S. appl.), 2 A 250 Vac 500 VA, 2 A 250 Vdc 80 W, resistive load (non I.S. appl.)
D5254	Relay	Alarm	4 A 250 Vac 1000 VA, 4 A 250 Vdc 120 W resistive load
D5264	Transistor	Alarm	100 mA at 60 V (≤ 1.0 V voltage drop)
D5273	Relay	Alarm	4 A 250 Vac 1000 VA, 4 A 250 Vdc 120 W resistive load
D5290	Relay	Load	10 A 250 Vac 2500 VA, 10 A 250 Vdc 300 W resistive load
D5290-078	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 175 W resistive load
D5291	Relay	Load	10 A 250 Vac 2500 VA, 10 A 250 Vdc 300 W resistive load
D5293	Relay	Fault 1	500 mA 30 Vac 15 VA, 500 mA 50 Vdc 25 W resistive load
	Relay	Fault 2	3 A 250 Vac 750 VA, 3 A 125 Vdc 120 W resistive load
	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load
D5294	Relay	Fault 1	500 mA 30 Vac 15 VA, 500 mA 50 Vdc 25 W resistive load
	Relay	Fault 2	3 A 250 Vac 750 VA, 3 A 125 Vdc 120 W resistive load
	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load
D5295	Relay	Fault 1	500 mA 30 Vac 15 VA, 500 mA 50 Vdc 25 W resistive load
	Relay	Fault 2	3 A 250 Vac 750 VA, 3 A 125 Vdc 120 W resistive load
	Relay	Load	5 A 250 Vac 1250 VA, 5 A 250 Vdc 140 W resistive load

3 Intrinsically safe parameters

D5011 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8, 9-10: U _o =25.9 V; I _o =92 mA; P _o =594 mW Characteristic: linear	IIC	0.1	4.2	59.9
	IIB	0.77	16.8	239.7
	IIA	2.63	33.7	479.4
	I	4.02	55.2	786.6
	IIIC	0.77	16.8	239.7

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5014 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8, 9-10: U _o =25.9 V; I _o =92 mA; P _o =594 mW Characteristic: linear	IIC	0.1	4.2	59.9
	IIB	0.77	16.8	239.7
	IIA	2.63	33.7	479.4
	I	4.02	55.2	786.6
	IIIC	0.77	16.8	239.7
Term. 10-12 (passive input), 8-11 (passive input): U _o =1.1 V; I _o =56 mA; P _o =16 mW U _i =30 V; I _i =128 mA; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	100	11.5	2327.2
	IIB	1000	46	9309
	IIA	1000	92.1	18618.1
	I	1000	151.1	30545.4
	IIIC	1000	46	9309

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5015 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8: U _o =26.8 V; I _o =92 mA; P _o =614 mW Characteristic: linear	IIC	0.092	4.2	57.9
	IIB	0.72	16.9	231.6
	IIA	2.37	33.8	463.3
	I	4.2	55.4	760.1
	IIIC	0.72	16.9	231.6
Term. 8-11 (passive input): U _o =1.1 V; I _o =56 mA; P _o =16 mW U _i =30 V; I _i =128 mA; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	100	11.5	2327.2
	IIB	1000	46	9309
	IIA	1000	92.1	18618.1
	I	1000	151.2	30545.4
	IIIC	1000	46	9309

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits.

D5016 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8, 9-10: U _o =8.8 V; I _o =0 mA; P _o =0 mW U _i =30 V; I _i =100 mA; C _i =1.1 nF; L _i =0 μH Characteristic: linear	IIC	5.4	1000	
	IIB	45.9	1000	
	IIA	729.9	1000	
	I	999.9	1000	
	IIIC	45.9	1000	

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5020 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8, 9-10: U _o =25.9 V; I _o =93 mA; P _o =595 mW Characteristic: linear	IIC	0.1	4.1	59.7
	IIB	0.77	16.7	239
	IIA	2.63	33.5	478.1
	I	4.02	54.9	784.5
	IIIC	0.77	16.7	239

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5030 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8, 9-10: U _o =10.5 V; I _o =22 mA; P _o =56 mW C _i =1.1 nF; L _i =0 μH Characteristic: linear	IIC	2.41	78.3	635.9
	IIB	16.8	313.4	2543.9
	IIA	75	626.9	5087.9
	I	66	1028.6	8347.4
	IIIC	16.8	313.4	2543.9

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5031 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8, 9-10: U _o =10.5 V; I _o =22 mA; P _o =56 mW C _i =1.1 nF; L _i =0 μH Characteristic: linear	IIC	2.41	78.3	635.9
	IIB	16.8	313.4	2543.9
	IIA	75	626.9	5087.9
	I	66	1028.6	8347.4
	IIIC	16.8	313.4	2543.9

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5032 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8, 9-10: U _o =10.5 V; I _o =22 mA; P _o =56 mW C _i =1.1 nF; L _i =0 μH Characteristic: linear	IIC	2.41	78.3	635.9
	IIB	16.8	313.4	2543.9
	IIA	75	626.9	5087.9
	I	66	1028.6	8347.4
	IIIC	16.8	313.4	2543.9

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5034 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8, 9-10: U _o =10.5 V; I _o =15 mA; P _o =39 mW Characteristic: linear	IIC	2.41	163.2	918.2
	IIB	16.8	652.8	3672.9
	IIA	75	1305.6	7345.8
	I	66	2142	12051.8
	IIIC	16.8	652.8	3672.9

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5036 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8, 9-10: U _o =10.5 V; I _o =22 mA; P _o =56 mW C _i =1.1 nF; L _i =0 μH Characteristic: linear	IIC	2.41	78.3	635.9
	IIB	16.8	313.4	2543.9
	IIA	75	626.9	5087.9
	I	66	1028.6	8347.4
	IIIC	16.8	33.4	2543.9

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5037 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8, 9-10: U _o =10.5 V; I _o =22 mA; P _o =56 mW C _i =1.1 nF; L _i =0 μH Characteristic: linear	IIC	2.41	78.3	635.9
	IIB	16.8	313.4	2543.9
	IIA	75	626.9	5087.9
	I	66	1028.6	8347.4
	IIIC	16.8	33.4	2543.9

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5038 series

		Co [μ F]	Lo [mH]	Lo/Ro [μ H/ Ω]
Term. 7-8, 9-10: U _o =10.5 V; I _o =22 mA; P _o =56 mW Characteristic: linear	IIC	2.4	78.3	635
	IIB	16.7	313.5	2543
	IIA	74.9	627.1	5087
	I	94.9	1028.8	8347
	IIIC	16.7	313.5	2543

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5039 series

		Co [μ F]	Lo [mH]	Lo/Ro [μ H/ Ω]
Term. 7-8, 9-10: U _o =10.5 V; I _o =22 mA; P _o =56 mW Characteristic: linear	IIC	2.4	78.3	635
	IIB	16.7	313.5	2543
	IIA	74.9	627.1	5087
	I	94.9	1028.8	8347
	IIIC	16.7	313.5	2543

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5040 series

		Co [μ F]	Lo [mH]	Lo/Ro [μ H/ Ω]
Term. 10-11 (Out A), 7-8 (Out A): U _o =25.2 V; I _o =146 mA; P _o =916 mW Characteristic: linear	IIC	0.107	1.67	38.8
	IIB	0.82	6.71	155.3
	IIA	2.9	13.42	310.7
	I	4.8	22.01	509.8
	IIIC	0.82	6.71	155.3
Term. 10-12 (Out B), 7-9 (Out B): U _o =25.2 V; I _o =108 mA; P _o =676 mW Characteristic: linear	IIC	0.107	3.07	52.6
	IIB	0.82	12.3	210.4
	IIA	2.9	24.61	420
	I	4.8	40.37	690.3
	IIIC	0.82	12.3	210.4
Term. 7//10-8//11 (Out A + Out A) (D5040D): U _o =25.2 V; I _o =292 mA; P _o =1831 mW Characteristic: linear	IIC	0	0	0
	IIB	0.82	1.67	77.6
	IIA	2.9	3.35	155.3
	I	4.8	5.5	254.9
	IIIC	0.82	1.67	77.6
Term. 7//10-9//12 (Out B + Out B) (D5040D): U _o =25.2 V; I _o =216 mA; P _o =1352 mW Characteristic: linear	IIC	0	0	0
	IIB	0.82	3.07	105.2
	IIA	2.9	6.15	210.4
	I	4.8	10.09	345.1
	IIIC	0.82	3.07	105.2
Term. 7//10-8//12 (Out A + Out B), 7//10-9//11 (Out A + Out B) (D5040D): U _o =25.2 V; I _o =254 mA; P _o =1592 mW Characteristic: linear	IIC	0	0	0
	IIB	0.82	2.22	89.3
	IIA	2.9	4.44	178.7
	I	4.8	7.28	293.2
	IIIC	0.82	2.22	89.3

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5048 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-10 (Out A): U ₀ =24.8 V; I ₀ =147 mA; P ₀ =907 mW Characteristic: linear	IIC	0.113	1.65	39.2
	IIB	0.86	6.63	156.8
	IIA	3.05	13.27	313.6
	I	4.35	21.78	514.6
	IIIC	0.86	6.63	156.8
Term. 8-10 (Out B): U ₀ =24.8 V; I ₀ =108 mA; P ₀ =667 mW Characteristic: linear	IIC	0.113	3.07	53.3
	IIB	0.86	12.3	213.5
	IIA	3.05	24.6	427
	I	4.35	40.36	700.6
	IIIC	0.86	12.3	213.5
Term. 9-10 (Out C): U ₀ =24.8 V; I ₀ =93 mA; P ₀ =571 mW Characteristic: linear	IIC	0.113	4.19	62.3
	IIB	0.86	16.79	249.4
	IIA	3.05	33.58	498.9
	I	4.35	55.09	818.5
	IIIC	0.86	16.79	249.4

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits.

D5049 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-10 (Out A): U ₀ =24.8 V; I ₀ =147 mA; P ₀ =907 mW Characteristic: linear	IIC	0.113	1.65	39.2
	IIB	0.86	6.63	156.8
	IIA	3.05	13.27	313.6
	I	4.35	21.78	514.6
	IIIC	0.86	6.63	156.8
Term. 8-10 (Out B): U ₀ =24.8 V; I ₀ =108 mA; P ₀ =667 mW Characteristic: linear	IIC	0.113	3.07	53.3
	IIB	0.86	12.3	213.5
	IIA	3.05	24.6	427
	I	4.35	40.36	700.6
	IIIC	0.86	12.3	213.5
Term. 9-10 (Out C): U ₀ =24.8 V; I ₀ =93 mA; P ₀ =571 mW Characteristic: linear	IIC	0.113	4.19	62.3
	IIB	0.86	16.79	249.4
	IIA	3.05	33.58	498.9
	I	4.35	55.09	818.5
	IIIC	0.86	16.79	249.4

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits.

D5062 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 7-8-9-10: U ₀ =27 V; I ₀ =90 mA; P ₀ =576 mW Characteristic: linear	IIC	0.09	4.1	56.8
	IIB	0.7	16.4	227.3
	IIA	2.3	33.9	454.7
	I	3.75	54	746.1
	IIIC	0.7	16.4	227.3
Term. 7/9-8 (with 2 wires constant current supply): U ₀ =27 V; I ₀ =90 mA; P ₀ =576 mW U _i =30 V; I _i =91 mA; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	0.09	4.1	56.8
	IIB	0.7	16.4	227.3
	IIA	2.3	33.9	454.7
	I	3.75	54	746.1
	IIIC	0.7	16.4	227.3

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits.

D5072 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 10-11-12, 7-8-9 (D5072D): U _o =7.2 V; I _o =16 mA; P _o =27 mW U _i =12.8 V; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	13.5	138	1290
	IIB	240	555	5160
	IIA	1000	1111	10330
	I	1000	1822	16950
	IIIC	240	555	5160
Term. 7-8-9-10 (D5072S): U _o =7.2 V; I _o =23 mA; P _o =40 mW U _i =12.8 V; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	13.5	67.2	875
	IIB	240	268.8	3500
	IIA	1000	537.7	7000
	I	1000	882.2	11480
	IIIC	240	268.8	3500

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5072-087 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 10-11-12, 7-8-9 (D5072D-087): U _o =7.2 V; I _o =16 mA; P _o =27 mW U _i =12.8 V; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	13.5	138	1290
	IIB	240	555	5160
	IIA	1000	1111	10330
	I	1000	1822	16950
	IIIC	240	555	5160
Term. 7-8-9-10 (D5072S-087): U _o =7.2 V; I _o =23 mA; P _o =40 mW U _i =12.8 V; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	13.5	67.2	875
	IIB	240	268.8	3500
	IIA	1000	537.7	7000
	I	1000	882.2	11480
	IIIC	240	268.8	3500

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5072-096 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 11-12, 7-8 (D5072D-096): U _o =7.2 V; I _o =16 mA; P _o =27 mW U _i =12.8 V; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	13.5	138	1290
	IIB	240	555	5160
	IIA	1000	1111	10330
	I	1000	1822	16950
	IIIC	240	555	5160
Term. 7-8 (D5072S-096): U _o =7.2 V; I _o =23 mA; P _o =40 mW U _i =12.8 V; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	13.5	67.2	875
	IIB	240	268.8	3500
	IIA	1000	537.7	7000
	I	1000	882.2	11480
	IIIC	240	268.8	3500

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5072-099 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 10-11-12, 7-8-9 (D5072D-099): U _o =7.2 V; I _o =16 mA; P _o =27 mW U _i =12.8 V; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	13.5	138	1290
	IIB	240	555	5160
	IIA	1000	1111	10330
	I	1000	1822	16950
	IIIC	240	555	5160
Term. 7-8-9-10 (D5072S-099): U _o =7.2 V; I _o =23 mA; P _o =40 mW U _i =12.8 V; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	13.5	67.2	875
	IIB	240	268.8	3500
	IIA	1000	537.7	7000
	I	1000	882.2	11480
	IIIC	240	268.8	3500

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5212 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 13-14, 15-16, 17-18, 19-20: U _o =24.1 V; I _o =86 mA; P _o =516 mW Characteristic: linear	IIC	0.121	4.85	68.9
	IIB	0.917	19.43	275.9
	IIA	3.307	38.86	551.9
	I	5.197	63.76	905.6
	IIIC	0.917	19.43	275.9
Term. 21-22, 23-24: U _o =1.1 V; I _o =56 mA; P _o =16 mW U _i =30 V; I _i =128 mA; C _i =2.1 nF; L _i =0 μH Characteristic: linear	IIC	99	11.63	2339
	IIB	999	46.54	9356.1
	IIA	999	93.09	18712.2
	I	999	152.73	30699.7
	IIIC	999	46.54	9356.1

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is not provided between separated intrinsically safe circuits.

D5231 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 21-13, 21-14, 22-15, 22-16, 23-17, 23-18, 24-19, 24-20: U _o =10.9 V; I _o =12 mA; P _o =31 mW C _i =11 nF Characteristic: linear	IIC	2	270	1147
	IIB	14.3	1000	4590
	IIA	62.9	1000	9181
	I	69.9	1000	15063
	IIIC	14.3	1000	4590

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is not provided between separated intrinsically safe circuits.

D5240 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 13-14 (Out A), 17-18 (Out A), 21-22 (Out A): U _o =25.2 V; I _o =146 mA; P _o =916 mW C _i =11 nF Characteristic: linear	IIC	0.096	1.67	38.8
	IIB	0.809	6.71	155.3
	IIA	2.889	13.42	310.7
	I	4.789	22.01	509.8
	IIIC	0.809	6.71	155.3

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 13//17//21 (Out A + Out A + Out C): U _o =25.2 V; I _o =384 mA; P _o =2138 mW C _i =33 nF Characteristic: linear	IIC	0	0	0
	IIB	0	0	0
	IIA	2.867	1.93	118
	I	4.767	3.17	193.6
	IIIC	0.787	0.96	59
Term. 13//17//21 (Out A + Out A + Out A): U _o =25.2 V; I _o =437 mA; P _o =2138 mW C _i =33 nF Characteristic: linear	IIC	0	0	0
	IIB	0	0	0
	IIA	2.867	1.49	103.5
	I	4.767	2.44	169.9
	IIIC	0	0	0
Term. 13-15 (Out B), 17-19 (Out B), 21-23 (Out B): U _o =25.2 V; I _o =108 mA; P _o =676 mW C _i =11 nF Characteristic: linear	IIC	0.096	3.07	52.6
	IIB	0.809	12.3	210.4
	IIA	2.889	24.61	420
	I	4.789	40.37	690.3
	IIIC	0.809	12.3	210.4
Term. 13-16 (Out C), 17-20 (Out C), 21-24 (Out C): U _o =25.2 V; I _o =93 mA; P _o =580 mW C _i =11 nF Characteristic: linear	IIC	0.096	4.18	61.3
	IIB	0.809	16.72	245.3
	IIA	2.889	33.45	490.6
	I	4.789	54.88	804.9
	IIIC	0.809	16.72	245.3
Term. 13//17-16//20 (Out C + Out C), 13//21-16//24 (Out C + Out C), 17//21-20//24 (Out C + Out C): U _o =25.2 V; I _o =185 mA; P _o =1160 mW C _i =22 nF Characteristic: linear	IIC	0	0	0
	IIB	0.798	4.18	122.6
	IIA	2.878	8.36	245.3
	I	4.778	13.72	402.4
	IIIC	0.798	4.18	122.6
Term. 13//17-15//19 (Out B + Out B), 13//21-15//23 (Out B + Out B), 17//21-19//23 (Out B + Out B): U _o =25.2 V; I _o =216 mA; P _o =1352 mW C _i =22 nF Characteristic: linear	IIC	0	0	0
	IIB	0.798	3.07	105.2
	IIA	2.878	6.15	210.4
	I	4.778	10.09	345.1
	IIIC	0.798	3.07	105.2
Term. 13//17-14//20 (Out A + Out C), 13//21-14//24 (Out A + Out C), 17//13-18//16 (Out A + Out C): U _o =25.2 V; I _o =238 mA; P _o =1496 mW C _i =22 nF Characteristic: linear	IIC	0	0	0
	IIB	0.798	2.51	95.1
	IIA	2.878	5.03	190.2
	I	4.778	8.25	312.1
	IIIC	0.798	2.51	95.1
Term. 13//17//21 (Out C + Out C + Out C): U _o =25.2 V; I _o =277 mA; P _o =1740 mW C _i =33 nF Characteristic: linear	IIC	0	0	0
	IIB	0.787	1.85	81.7
	IIA	2.867	3.71	163.5
	I	4.767	6.09	268.3
	IIIC	0.787	1.85	81.7
Term. 13//17//21 (Out B + Out B + Out B): U _o =25.2 V; I _o =323 mA; P _o =2028 mW C _i =33 nF Characteristic: linear	IIC	0	0	0
	IIB	0.787	1.36	70.1
	IIA	2.867	2.73	140.2
	I	4.767	4.48	230.1
	IIIC	0.787	1.36	70.1
Term. 13//17//21 (Out A + Out B + Out B): U _o =25.2 V; I _o =361 mA; P _o =2138 mW C _i =33 nF Characteristic: linear	IIC	0	0	0
	IIB	0	0	0
	IIA	2.867	2.18	125.4
	I	4.767	3.58	205.8
	IIIC	0.787	1.09	62.7

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is not provided between separated intrinsically safe circuits.

D5244 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 13-14-15/16, 17-18-19/20: U _o =0 V; I _o =0 mA; P _o =0 mW U _i =40 V; I _i =2 A; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC			
	IIB			
	IIA			
	I			
	IIIC			

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits. Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between separated intrinsically safe circuits.

D5254 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 13-14: U _o =26 V; I _o =91 mA; P _o =588 mW C _i =2.1 nF; L _i =0 μH Characteristic: linear	IIC	0.096	4.34	0
	IIB	0.767	17.36	242.2
	IIA	2.597	34.72	484.4
	I	4.497	56.96	794.7
	IIIC	0.767	17.36	242.2
Term. 14-16: U _o =1.1 V; I _o =56 mA; P _o =16 mW U _i =30 V; I _i =126 mA; C _i =2.1 nF; L _i =0 μH Characteristic: linear	IIC	100	11.5	1000
	IIB	1000	46	9356
	IIA	1000	92.1	18712
	I	1000	100	30699
	IIIC	1000	46	9356
Term. 15-16: U _o =1.1 V; I _o =12 μA; P _o =4 μW U _i =30 V; C _i =2.1 nF; L _i =0 μH Characteristic: linear	IIC	100	100	1000
	IIB	1000	100	1000
	IIA	1000	100	1000
	I	1000	100	1000
	IIIC	1000	100	1000

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits.

D5263 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 13-14-15-16-17-18: U _o =7.2 V; I _o =177 mA; P _o =471 mW C _i =1.1 μF Characteristic: trapezoidal	IIC	0.5	0.5	0
	IIB	2.6	8.7	0
	IIA	11.9	16	0
	I	10.9	29	0
	IIIC	2.6	8.7	0

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits.

D5264 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 13-14-15-16-17-18: U _o =7.2 V; I _o =177 mA; P _o =471 mW C _i =1.1 μF Characteristic: trapezoidal	IIC	0.5	0.5	0
	IIB	2.6	8.7	0
	IIA	11.9	16	0
	I	10.9	29	0
	IIIC	2.6	8.7	0

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits.

D5273 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 13-14-15-16: U _o =7.2 V; I _o =23 mA; P _o =40 mW U _i =12.8 V; I _i =28.7 mA; C _i =0 nF; L _i =0 μH Characteristic: linear	IIC	13.5	67.2	875
	IIB	240	268.8	3500
	IIA	1000	537.7	7000
	I	1000	882.2	11480
	IIIC	240	268.8	3500

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits.

PSD5201 series

		Co [uF]	Lo [mH]	Lo/Ro [uH/Ω]
Term. 13/15-14/16: U _o =21.5 V; I _o =604 mA; P _o =3243 mW Characteristic: linear	IIC	0	0	0
	IIB	1.2	0.39	43.8
	IIA	4.5	0.78	87.7
	I	6.5	1.28	143.9
	IIIC	1.2	0.39	43.8

Isolation in accordance with EN/IEC 60079-11 (GOST 31610.11) clause 6.3.13 is provided between non-intrinsically safe circuits and intrinsically safe circuits.

www.gminternational.com



Via G. Mameli, 53/55
I-20851 Villasanta (MB) - Italy

Note: This manual contains only safety instructions.

For the complete installation and user manuals, data sheets and certificates, supplier code of conduct, code of ethics, terms and conditions of sale and warranty please refer to www.gminternational.com.